

AIR QUALITY TIER I OPERATING PERMIT NUMBER: 029-00003

Permittee: Nu-West Industries, Inc.; Agrium Conda
Phosphate Operations
Location: Soda Springs, Idaho

Date Issued: October 28, 2002
Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

8. CLEAVER-BROOKS BOILER

Summary Description

The following is a narrative description of the Cleaver-Brooks boiler regulated in this Tier I operating permit. This description is for informational purposes only.

The Cleaver-Brooks boiler supplies steam to the purified phosphoric acid (PPA) plant. The boiler's steam-generating capacity is approximately 150,000 pounds per hour.

Table 8.1 describes the devices used to control emissions from the Cleaver-Brooks boiler.

Table 8.1 EMISSIONS UNITS AND EMISSIONS CONTROL DEVICES

Source Code	Emission Unit(s)/Process(es)	Emission Control Device
A-Cb-1	Cleaver-Brooks boiler	Low-NO _x package boiler

Table 8.2 contains only a summary of the requirements that apply to the Cleaver-Brooks boiler. Specific permit requirements are listed below Table 8.2.

Table 8.2 APPLICABLE REQUIREMENTS SUMMARY

Permit Conditions	Parameter	Permit Limit / Standard Summary	Applicable Requirements Reference	Monitoring & Recordkeeping Requirements
8.1	Nitrogen oxide emissions	33 T/yr	PTC No. 029-00003, pg. 22, Permit Condition 1.1	8.4, 8.13
8.2	Nitrogen oxide emissions	0.10 lb/MMBtu heat input to the boiler at a low heat release rate (70,000 Btu/hr-ft ² or less), 0.20 lb/MMBtu heat input to the boiler at a high-heat release rate (greater than 70,000 Btu/hr-ft ²)	40 CFR 60.44b(a) ⁽¹⁾	8.4, 8.5, 8.6, 8.7, 8.8, 8.9, 8.10, 8.11, 8.12, 8.13, 8.14, 8.15, 8.16, 8.17, 8.18, 8.19
8.3	Particulate matter	0.015 gr/dscf corrected to 3% oxygen	IDAPA 58.01.01.676	8.4

¹ If any requirement in this permit conflicts with any requirement contained in 40 CFR 60 the requirement in 40 CFR 60 shall control.

Permit Limits / Standard Summary

8.1 NO_x Emission Limits

The NO_x emissions from the boiler stack shall not exceed 33 T/yr. As determined by a pollutant-specific EPA reference method, the Department-approved alternative, or as determined by the Department's emission estimation methods used in the PTC application analysis.

[IDAPA 58.01.01.211.01, 5/1/94; PTC No. 029-00003, pg. 22, Permit Condition 1.1, 7/12/00]

AIR QUALITY TIER I OPERATING PERMIT NUMBER: 029-00003

Permittee: Nu-West Industries, Inc.; Agrium Conda
Phosphate Operations
Location: Soda Springs, Idaho

Date Issued: October 28, 2002
Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

8.2 NSPS NO_x Emission Limits

On and after the date the initial performance test is completed, or is required to be completed under 40 CFR 60.8 (whichever comes first), the permittee shall not cause any gases that contain nitrogen oxides (expressed as NO₂) to be discharged into the atmosphere in excess of 0.10 pounds per million Btu (0.10 lb/MMBtu) heat input to the boiler at a low heat release rate (70,000 Btu/hr-ft³ or less), or in excess of 0.20 pounds per million Btu (0.20 lb/MMBtu) heat input to the boiler at a high heat release rate (greater than 70,000 Btu/hr-ft³).

[40 CFR 60.44b(a)(1); PTC No. 029-00003, pg. 22, Permit Condition 1.2, 7/12/00]

8.2.1 For purposes of compliance with 40 CFR 60.44b(i) (Permit Condition 8.2.2), the nitrogen oxide standards in Permit Condition 8.2 apply at all times including periods of startup, shutdown, or malfunction.
[40 CFR 60.44b(h)]

8.2.2 Except as provided in Permit Condition 8.2.3, compliance with the emissions limits in Permit Condition 8.2 is determined on a 30-day rolling average basis.
[40 CFR 60.44b(i); PTC No. 029-00003, pg. 22, Permit Condition 1.2.1, 7/12/00]

8.2.3 Compliance with the emission limits under this section is determined on a 24-hour average basis for the initial performance test and on a three-hour average basis for subsequent performance tests for any affected facilities that:

- (1) Combust, alone or in combination, only natural gas, distillate oil, or residual oil with a nitrogen content of 0.30 weight percent or less;
- (2) Have a combined annual capacity factor of 10% or less for natural gas, distillate oil, and residual oil with a nitrogen content of 0.30 weight percent or less; and
- (3) Are subject to a Federally enforceable requirement limiting operation of the affected facility to the firing of natural gas, distillate oil, and/or residual oil with a nitrogen content of 0.30 weight percent or less and limiting operation of the affected facility to a combined annual capacity factor of 10% or less for natural gas, distillate oil, and residual oil and a nitrogen content of 0.30 weight percent or less.

[40 CFR 60.44b(j)]

8.3 The PM emissions shall not exceed the grain loading emission limits of 0.015 gr/dscf of effluent gas corrected to 3% oxygen by volume for natural gas.

[IDAPA 58.01.01.676, 5/1/94] Operating Requirements

8.4 Fuel Specification

The boiler shall use only natural gas as fuel.

[IDAPA 58.01.01.211.01, 5/1/94; PTC No. 029-00003, pg. 22, Permit Condition 2.1, 7/12/00]

8.5 Performance Tests

8.5.1 Within 60 days after achieving the maximum production rate at which the affected facility will be operated, but not later than 180 days after initial startup of such facility and at such other times as may be required by the Administrator under Section 114 of the Act, the owner or operator of such facility shall conduct performance test(s) and furnish the Administrator a written report of the results of such performance test(s).

[40 CFR 60.8(a)]

AIR QUALITY TIER I OPERATING PERMIT NUMBER: 029-00003

Permittee: Nu-West Industries, Inc.; Agrium Conda
Phosphate Operations
Location: Soda Springs, Idaho

Date Issued: October 28, 2002
Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

- 8.5.2 Performance tests shall be conducted and data reduced in accordance with the test methods and procedures contained in each applicable subpart unless the Administrator:
- (1) specifies or approves, in specific cases, the use of a reference method with minor changes in methodology,
 - (2) approves the use of an equivalent method,
 - (3) approves the use of an alternative method the results of which he has determined to be adequate for indicating whether a specific source is in compliance,
 - (4) waives the requirement for performance tests because the owner or operator of a source has demonstrated by other means to the Administrator's satisfaction that the affected facility is in compliance with the standard, or
 - (5) approves shorter sampling times and smaller sample volumes when necessitated by process variables or other factors. Nothing in this paragraph shall be construed to abrogate the Administrator's authority to require testing under Section 114 of the Clean Air Act.
- [40 CFR 60.8(b)]
- 8.5.3 Performance tests shall be conducted under such conditions as the Administrator shall specify to the plant operator based on representative performance of the affected facility. The owner or operator shall make available to the Administrator such records as may be necessary to determine the conditions of the performance tests. Operations during periods of startup, shutdown, and malfunction shall not constitute representative conditions for the purpose of a performance test nor shall emissions in excess of the level of the applicable emission limit during periods of startup, shutdown, and malfunction be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard.
- [40 CFR 60.8(c)]
- 8.5.4 The owner or operator of an affected facility shall provide the Administrator at least 30 days prior notice of any performance test, except as specified under other subparts, to afford the Administrator the opportunity to have an observer present. If after 30 days notice for an initially scheduled performance test, there is a delay (due to operational problems, etc.) in conducting the scheduled performance test, the owner or operator of an affected facility shall notify the Administrator (or delegated State or local agency) as soon as possible of any delay in the original test date, either by providing at least seven days prior notice of the rescheduled date of the performance test, or by arranging a rescheduled date with the Administrator (or delegated State or local agency) by mutual agreement.
- [40 CFR 60.8(d)]
- 8.5.5 The owner or operator of an affected facility shall provide, or cause to be provided, performance testing facilities as follows:
- (1) Sampling ports adequate for test methods applicable to such facility. This includes (i) constructing the air pollution control system such that volumetric flow rates and pollutant emission rates can be accurately determined by applicable test methods and procedures and (ii) providing a stack or duct free of cyclonic flow during performance tests, as demonstrated by applicable test methods and procedures.
 - (2) Safe sampling platform(s).
 - (3) Safe access to sampling platform(s).

AIR QUALITY TIER I OPERATING PERMIT NUMBER: 029-00003

Permittee: Nu-West Industries, Inc.; Agrium Conda
Phosphate Operations
Location: Soda Springs, Idaho

Date Issued: October 28, 2002
Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

- (4) Utilities for sampling and testing equipment.

[40 CFR 60.8(e)]

- 8.5.6 Unless otherwise specified in the applicable subpart, each performance test shall consist of three separate runs using the applicable test method. Each run shall be conducted for the time and under the conditions specified in the applicable standard. For the purpose of determining compliance with an applicable standard, the arithmetic means of results of the three runs shall apply. In the event that a sample is accidentally lost or conditions occur in which one of the three runs must be discontinued because of forced shutdown, failure of an irreplaceable portion of the sample train, extreme meteorological conditions, or other circumstances, beyond the owner or operator's control, compliance may, upon the Administrator's approval, be determined using the arithmetic mean of the results of the two other runs.

[40 CFR 60.8(f)]

8.6 Compliance with Standards

At all times, including periods of startup, shutdown, and malfunction, owners and operators shall, to the extent practicable, maintain and operate any affected facility including associated air pollution control equipment in a manner consistent with good air pollution control practice for minimizing emissions. Determination of whether acceptable operating and maintenance procedures are being used will be based on information available to the Administrator which may include, but is not limited to, monitoring results, opacity observations, review of operating and maintenance procedures, and inspection of the source.

[40 CFR 60.11(d)]

- 8.7 For the purpose of submitting compliance certifications or establishing whether or not a person has violated or is in violation of any standard in 40 CFR 60, nothing in 40 CFR 60 shall preclude the use, including the exclusive use, of any credible evidence or information, relevant to whether a source would have been in compliance with applicable requirements if the appropriate performance or compliance test or procedure had been performed.

[40 CFR 60.11(g)]

8.8 Circumvention

No owner or operator subject to the provisions of 40 CFR 60 shall build, erect, install, or use any article, machine, equipment or process, the use of which conceals an emission which would otherwise constitute a violation of an applicable standard. Such concealment includes, but is not limited to, the use of gaseous diluents to achieve compliance with an opacity standard or with a standard which is based on the concentration of a pollutant in the gases discharged to the atmosphere.

[40 CFR 60.12]

Monitoring & Recordkeeping Requirements

8.9 NO_x Performance Test

Compliance with the nitrogen oxides emission standards under Permit Condition 8.2 (40 CFR 60.44b) and the annual emission limit in Permit Condition 8.1 shall be determined through performance testing under 40 CFR 60.46b(e) or (g). This performance test, and any subsequent performance tests conducted to demonstrate compliance with this permit, shall be performed in accordance with IDAPA 58.01.01.157 and Permit Condition 8.21.

[40 CFR 60.46b(c); PTC No. 029-00003, pg. 23, Permit Condition 3.1, 7/12/00]

AIR QUALITY TIER I OPERATING PERMIT NUMBER: 029-00003

Permittee: Nu-West Industries, Inc.; Agrium Conda
Phosphate Operations
Location: Soda Springs, Idaho

Date Issued: October 28, 2002
Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

8.10 To determine compliance with the emission limits for nitrogen oxides required under 40 CFR 60.44b, the owner or operator of an affected facility shall conduct the performance test as required under 40 CFR 60.8 using the continuous system for monitoring nitrogen oxides under 40 CFR 60.48(b).

- (1) For the initial compliance test, nitrogen oxides from the steam-generating unit are monitored for 30 successive steam generating unit operating days and the 30-day average emission rate is used to determine compliance with the nitrogen oxides emission standards under 40 CFR 60.44b. The 30-day average emission rate is calculated as the average of all hourly emissions data recorded by the monitoring system during the 30-day test period.
- (2) Not applicable to natural gas-fired boiler.
- (3) Not applicable to boiler less than 250 million Btu/hour heat input capacity.
- (4) Following the date on which the initial performance test is completed or required to be completed under 40 CFR 60.8 of 40 CFR 60, whichever date comes first, the owner or operator of an affected facility which has a heat input capacity of 73 MW (250 million Btu/hour) or less and which combusts natural gas, distillate oil, or residual oil having a nitrogen content of 0.30 weight percent or less shall upon request determine compliance with the nitrogen oxides standards under 40 CFR 60.44b through the use of a 30-day performance. During periods when performance tests are not requested, nitrogen oxides emissions data collected pursuant to 40 CFR 60.48b(g)(1) or 40 CFR 60.48b(g)(2) are used to calculate a 30-day rolling average emission rate on a daily basis and used to prepare excess emission reports, but will not be used to determine compliance with the nitrogen oxides emission standards. A new 30-day rolling-average-emission rate is calculated each steam-generating unit operating day as the average of all of the hourly nitrogen oxides emission data for the preceding 30 steam-generating unit operating days.

[40 CFR 60.46b(e)]

8.11 The owner or operator of an affected facility described in 40 CFR 60.44b(j) or 40 CFR 60.44b(k) shall demonstrate the maximum heat input capacity of the steam generating unit by operating the facility at maximum capacity for 24 hours. The owner or operator of an affected facility shall determine the maximum heat input capacity using the heat loss method described in Sections 5 and 7.3 of the ASME Power Test Codes 4.1 (see IBR 40 CFR 60.17(h)). This demonstration of maximum heat input capacity shall be made during the initial performance test for affected facilities that meet the criteria of 40 CFR 60.44b(j). It shall be made within 60 days after achieving the maximum production rate at which the affected facility will be operated, but no later than 180 days after initial start-up of each facility, for affected facilities meeting the criteria of 40 CFR 60.44b(k). Subsequent demonstrations may be required by the Administrator at any other time. If this demonstration indicates that the maximum heat input capacity of the affected facility is less than that stated by the manufacturer of the affected facility, the maximum heat input capacity determined during this demonstration shall be used to determine the capacity utilization rate for the affected facility. Otherwise, the maximum heat input capacity provided by the manufacturer is used.

[40 CFR 60.46b(g)]

AIR QUALITY TIER I OPERATING PERMIT NUMBER: 029-00003

Permittee: Nu-West Industries, Inc.; Agrium Conda
Phosphate Operations
Location: Soda Springs, Idaho

Date Issued: October 28, 2002
Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

8.12 NO_x Monitoring, Recordkeeping, and Reporting

The permittee shall comply with either the continuous monitoring system requirements under Permit Condition 8.13 (40 CFR 60.48b(b) through 60.48b(f)) or the predictive monitoring requirements under Permit Condition 8.14 (40 CFR 60.48b(g)) to demonstrate compliance with the nitrogen oxides emission monitoring requirements specified in 40 CFR 60.48b.

[40 CFR 60.48b, 60.49b; PTC No. 029-00003, pg. 23, Permit Condition 3.2, 7/12/00]

8.13 Except as provided under paragraphs (g), (h), and (i) of this section, the owner or operator of an affected facility shall comply with either paragraphs (b)(1) or (b)(2) of this section.

- (1) Install, calibrate, maintain, and operate a continuous monitoring system, and record the output of the system, for measuring nitrogen oxides emissions discharged to the atmosphere; or
- (2) If the owner or operator has installed a nitrogen oxides emission rate continuous emission monitoring system (CEMS) to meet the requirements of Part 75 of 40 CFR and is continuing to meet the ongoing requirements of Part 75 of 40 CFR, that CEMS may be used to meet the requirements of this section, except that the owner or operator shall also meet the requirements of 40 CFR 60.49b. Data reported to meet the requirements of 40 CFR 60.49b shall not include data substituted using the missing data procedures in Subpart D of Part 75 of 40 CFR, nor shall the data have been bias adjusted according to the procedures of 40 CFR Part 75.

[40 CFR 60.48b(b)]

8.13.1 The continuous monitoring systems required under paragraph (b) of this section shall be operated and data recorded during all periods of operation of the affected facility except for continuous monitoring system breakdowns and repairs. Data is recorded during calibration checks, and zero and span adjustments.

[40 CFR 60.48b(c)]

8.13.2 The one-hour average NO_x emission rates measured by the continuous nitrogen oxides monitor required by paragraph (b) of this section and required under 40 CFR 60.13(h) shall be expressed in ng/J or lb/million Btu heat input and shall be used to calculate the average emission rates under 40 CFR 60.44b. The one-hour averages shall be calculated using the data points required under 40 CFR 60.13(b). At least two data points must be used to calculate each one-hour average.

[40 CFR 60.48b(d)]

8.13.1 The procedures under 40 CFR 60.13 shall be followed for installation, evaluation, and operation of the continuous monitoring systems.

- (1) For affected facilities burning coal, wood or municipal-type solid waste, the span value for a continuous monitoring system for measuring opacity shall be between 60 and 80%.
- (2) For affected facilities combusting natural gas, the span value for NO_x is determined as follows:

Span Values for Fuel

Nitrogen Oxides (PPM)

Natural gas

500

[40 CFR 60.48b(e)]

AIR QUALITY TIER I OPERATING PERMIT NUMBER: 029-00003

Permittee: Nu-West Industries, Inc.; Agrium Conda
Phosphate Operations
Location: Soda Springs, Idaho

Date Issued: October 28, 2002
Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

- 8.13.4 When NO_x emission data is not obtained because of continuous monitoring system breakdowns, repairs, calibration checks and zero and span adjustments, emission data will be obtained by using standby monitoring systems, Method 7, Method 7A, or other approved reference methods to provide emission data for a minimum of 75% of the operating hours in each steam generating unit operating day, in at least 22 out of 30 successive steam generating unit operating days.

[40 CFR 60.48b(f)]

- 8.14 The owner or operator of an affected facility that has a heat input capacity of 73 MW (250 MMBtu/hour) or less, and which has an annual capacity factor for residual oil having a nitrogen content of 0.30 weight percent or less, natural gas, distillate oil, or any mixture of these fuels, greater than 10% shall:

- (1) Comply with the provisions of Permit Condition 8.13, or
- (2) Monitor steam generating unit operating conditions and predict nitrogen oxides emission rates as specified in a plan submitted pursuant to Permit Condition 8.16 (40 CFR 60.49b(c)).

[40 CFR 60.48b(g)]

8.15 40 CFR 60, Subpart A Monitoring Requirements

- 8.15.1 For the purposes of this section, all continuous monitoring systems required under applicable subparts shall be subject to the provisions of this section upon promulgation of performance specifications for continuous monitoring systems under Appendix B to 40 CFR 60, and, if the continuous monitoring system is used to demonstrate compliance with emission limits on a continuous basis, Appendix F to 40 CFR 60, unless specified in an applicable subpart or by the Administrator. Appendix F is applicable December 4, 1987.

[40 CFR 60.13(a)]

- 8.15.2 All continuous monitoring systems and monitoring devices shall be installed and operational prior to conducting performance tests under 40 CFR 60.8. Verification of operational status shall, as a minimum, include completion of the manufacturer's written requirements or recommendations for installation, operation, and calibration of the device.

[40 CFR 60.13(b)]

- 8.15.3 Owners and operators of a CEMS installed in accordance with the provisions of 40 CFR 60, must automatically check the zero (or low level value between 0% and 20% of span value) and span (50% to 100% of span value) calibration drifts at least once daily in accordance with a written procedure. The zero and span must, as a minimum, be adjusted whenever either the 24-hour zero drift or the 24-hour span drift exceeds two times the limit of the applicable performance specification in Appendix B of 40 CFR 60. The system must allow the amount of the excess zero and span drift to be recorded and quantified whenever specified.

- (1) Owners and operators of a COMS installed in accordance with the provisions of 40 CFR 60, must automatically, intrinsic to the opacity monitor, check the zero and upscale (span) calibration drifts at least once daily. For a particular COMS, the acceptable range of zero and upscale calibration materials is as defined in the applicable version of PS-1 in Appendix B of 40 CFR 60. For continuous monitoring systems measuring opacity of emissions not using automatic zero adjustments, the optical surfaces exposed to the effluent gases shall be cleaned prior to performing the zero and span drift adjustments. For systems using automatic zero adjustments, the optical surfaces shall be cleaned when the cumulative automatic zero compensation exceeds 4% opacity.

AIR QUALITY TIER I OPERATING PERMIT NUMBER: 029-00003

Permittee: Nu-West Industries, Inc.; Agrium Conda
Phosphate Operations
Location: Soda Springs, Idaho

Date Issued: October 28, 2002
Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

- (2) Unless otherwise approved by the Administrator, the following procedures must be followed for a COMS. Minimum procedures must include an automated method for producing a simulated zero opacity condition and an upscale opacity condition using a certified neutral density filter or other related technique to produce a known obstruction of the light beam. Such procedures must provide a system check of all active analyzer internal optics with power or curvature, all active electronic circuitry including the light source and photodetector assembly, and electronic or electro-mechanical systems and hardware and or software used during normal measurement operation.

[40 CFR 60.13(d)]

8.15.4 Except for system breakdowns, repairs, calibration checks, and zero and span adjustments required under paragraph (d) of this section, all continuous monitoring systems shall be in continuous operation and shall meet minimum frequency of operation requirements as follows:

- (1) All continuous monitoring systems referenced by paragraph (c) of this section for measuring opacity of emissions shall complete a minimum of one cycle of sampling and analyzing for each successive 10-second period and one cycle of data recording for each successive six-minute period.
- (2) All continuous monitoring systems referenced by paragraph (c) of this section for measuring emissions, except opacity, shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period.

[40 CFR 60.13(e)]

8.15.5 All continuous monitoring systems or monitoring devices shall be installed such that representative measurements of emissions or process parameters from the affected facility are obtained. Additional procedures for location of continuous monitoring systems contained in the applicable Performance Specifications of Appendix B of 40 CFR 60 shall be used.

[40 CFR 60.13(f)]

8.15.6 Owners or operators of all continuous monitoring systems for measurement of opacity shall reduce all data to six-minute averages and for continuous monitoring systems other than opacity to one-hour averages for time periods as defined in 40 CFR 60.2. Six-minute opacity averages shall be calculated from 36 or more data points equally spaced over each six-minute period. For continuous monitoring systems other than opacity, one-hour averages shall be computed from four or more data points equally spaced over each one-hour period. Data recorded during periods of continuous system breakdown, repair, calibration checks, and zero and span adjustments shall not be included in the data averages computed under this paragraph. For owners and operators complying with the requirements in 40 CFR 60.7(f)(1) or (2), data averages must include any data recorded during periods of monitor breakdown or malfunction. An arithmetic or integrated average of all data may be used. The data may be recorded in reduced or nonreduced form (e.g., ppm pollutant and percent OG22K or ng of pollutant per J of heat input). All excess emissions shall be converted into units of the standard using the applicable conversion procedures specified in subparts. After conversion into units of the standard, the data may be rounded to the same number of significant digits as used in the applicable subparts to specify the emission limit (e.g., rounded to the nearest 1% opacity).

[40 CFR 60.13(h)]

8.15.7 After receipt and consideration of written application, the Administrator may approve alternatives to any monitoring procedures or requirements of 40 CFR 60 including, but not limited to the following:

- (1) Alternative monitoring requirements when installation of a continuous monitoring system or monitoring device specified by 40 CFR 60 would not provide accurate measurements due to liquid water or other interferences caused by substances in the effluent gases.

AIR QUALITY TIER I OPERATING PERMIT NUMBER: 029-00003

Permittee: Nu-West Industries, Inc.; Agrium Conda
Phosphate Operations
Location: Soda Springs, Idaho

Date Issued: October 28, 2002
Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

- (2) Alternative monitoring requirements when the affected facility is infrequently operated.
- (3) Alternative monitoring requirements to accommodate continuous monitoring systems that require additional measurements to correct for stack moisture conditions.
- (4) Alternative locations for installing continuous monitoring systems or monitoring devices when the owner or operator can demonstrate that installation at alternate locations will enable accurate and representative measurements.
- (5) Alternative methods of converting pollutant concentration measurements to units of the standards.
- (6) Alternative procedures for performing daily checks of zero and span drift that do not involve use of span gases or test cells.
- (7) Alternatives to the A.S.T.M. test methods or sampling procedures specified by any subpart.
- (8) Alternative continuous monitoring systems that do not meet the design or performance requirements in Performance Specification 1, Appendix B, but adequately demonstrate a definite and consistent relationship between its measurements and the measurements of opacity by a system complying with the requirements in Performance Specification 1. The Administrator may require that such demonstration be performed for each affected facility.
- (9) Alternative monitoring requirements when the effluent from a single affected facility or the combined effluent from two or more affected facilities is released to the atmosphere through more than one point.

[40 CFR 60.13(I)]

8.15.8 An alternative to the relative accuracy (RA) test specified in Performance Specification 2 of 40 CFR 60, Appendix B may requested as follows:

- (1) An alternative to the reference method tests for determining RA is available for sources with emission rates demonstrated to be less than 50% of the applicable standard. A source owner or operator may petition the Administrator to waive the relative accuracy test in Section 8.4 of Performance Specification 2 and substitute the procedures in Section 16.0 if the results of a performance test conducted according to the requirements in 40 CFR 60.8 or other tests performed following the criteria in 40 CFR 60.8 demonstrate that the emission rate of the pollutant of interest in the units of the applicable standard is less than 50% of the applicable standard. For sources subject to standards expressed as control efficiency levels, a source owner or operator may petition the Administrator to waive the RA test and substitute the procedures in Section 16.0 of Performance Specification 2 if the control device exhaust emission rate is less than 50% of the level needed to meet the control efficiency requirement. The alternative procedures do not apply if the continuous emission monitoring system is used to determine compliance continuously with the applicable standard. The petition to waive the RA test shall include a detailed description of the procedures to be applied. Included shall be location and procedure for conducting the alternative, the concentration or response levels of the alternative RA materials, and the other equipment checks included in the alternative procedure. The Administrator will review the petition for completeness and applicability. The determination to grant a waiver will depend on the intended use of the CEMS data (e.g., data collection purposes other than NSPS) and may require specifications more stringent than in Performance Specification 2 (e.g., the application emission limit is more stringent than NSPS).

AIR QUALITY TIER I OPERATING PERMIT NUMBER: 029-00003

Permittee: Nu-West Industries, Inc.; Agrium Conda
Phosphate Operations
Location: Soda Springs, Idaho

Date Issued: October 28, 2002

Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

- (2) The waiver of a CEMS RA test will be reviewed and may be rescinded at such time, following successful completion of the alternative RA procedure, that the CEMS data indicate that the source emissions are approaching the level. The criterion for reviewing the waiver is the collection of CEMS data showing that emissions have exceeded 70% of the applicable standard for seven, consecutive, averaging periods as specified by the applicable regulation(s). For sources subject to standards expressed as control efficiency levels, the criterion for reviewing the waiver is the collection of CEMS data showing that exhaust emissions have exceeded 70% of the level needed to meet the control efficiency requirement for seven consecutive, averaging periods as specified by the applicable regulation(s) (e.g., 40 CFR 60.45(g)(2) and (3), 40 CFR 60.73(e), and 40 CFR 60.84(e)). It is the responsibility of the source operator to maintain records and determine the level of emissions relative to the criterion on the waiver of RA testing. If this criterion is exceeded, the owner or operator must notify the Administrator within 10 days of such occurrence and include a description of the nature and cause of the increasing emissions. The Administrator will review the notification and may rescind the waiver and require the owner or operator to conduct a RA test of the CEMS as specified in Section 8.4 of Performance Specification 2.

[40 CFR 60.13(j)]

Reporting

- 8.16 The owner or operator of each affected facility subject to the nitrogen oxides standard of 60.44b who seeks to demonstrate compliance with those standards through the monitoring of steam generating unit operating conditions under the provisions of 40 CFR 60.48b(g)(2) shall submit to the Administrator for approval a plan that identifies the operating conditions to be monitored under 40 CFR 60.48b(g)(2) and the records to be maintained under 40 CFR 60.49b(j). This plan shall be submitted to the Administrator for approval within 360 days of the initial startup of the affected facility. The plan shall:

- (1) Identify the specific operating conditions to be monitored and the relationship between these operating conditions and nitrogen oxides emission rates (i.e., ng/J or lbs/million Btu heat input). Steam generating unit operating conditions include, but are not limited to, the degree of staged combustion (i.e., the ratio of primary air to secondary and/or tertiary air) and the level of excess air (i.e., flue gas oxygen level);
- (2) Include the data and information which the owner or operator used to identify the relationship between nitrogen oxides emission rates and these operating conditions;
- (3) Identify how these operating conditions, including steam generating unit load, will be monitored under 40 CFR 60.48b(g) on an hourly basis by the owner or operator during the period of operation of the affected facility; the quality assurance procedures or practices that will be employed to ensure that the data generated by monitoring these operating conditions will be representative and accurate; and the type and format of the records of these operating conditions, including steam generating unit load, that will be maintained by the owner or operator under 40 CFR 60.49b(j). If the plan is approved, the owner or operator shall maintain records of predicted nitrogen oxide emission rates and the monitored operating conditions, including steam generating unit load, identified in the plan.

[40 CFR 60.49b(c)]

AIR QUALITY TIER I OPERATING PERMIT NUMBER: 029-00003

Permittee: Nu-West Industries, Inc.; Agrium Conda
Phosphate Operations
Location: Soda Springs, Idaho

Date Issued: October 28, 2002
Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

- 8.17 The owner or operator of an affected facility shall record and maintain records of the amounts of each fuel combusted during each day and calculate the annual capacity factor individually for coal, distillate oil, residual oil, natural gas, wood, and municipal-type solid waste for the reporting period. The annual capacity factor is determined on a 12-month rolling average basis with a new annual capacity factor calculated at the end of each calendar month.

[40 CFR 60.49b(d)]

8.18 Address

- 8.18.1 All requests, reports, applications, submittals, and other communications to the Administrator pursuant to 40 CFR 60 shall be submitted in duplicate to the appropriate Regional Office of the EPA to the attention of the Director of the Division indicated in the following list of EPA Regional Offices. Copies of all information required to be submitted to the EPA for applicable NSPS requirements, shall also be submitted to the Department at the address given in Permit Condition 1 of this permit.

Region 10
Director, Air and Waste Management Division
EPA
1200 Sixth Ave.
Seattle, WA 98101

[40 CFR 60.4(a); IDAPA 58.01.01.322.08]

8.19 Notification and recordkeeping

- 8.19.1 Any owner or operator subject to the provisions of 40 CFR 60 shall furnish the Administrator written notification or, if acceptable to both the Administrator and the owner or operator of a source, electronic notification, as follows:
- (1) A notification of the date construction (or reconstruction as defined under 40 CFR 60.15) of an affected facility is commenced postmarked no later than 30 days after such date. This requirement shall not apply in the case of mass-produced facilities which are purchased in completed form.
 - (2) (Reserved).
 - (3) A notification of the actual date of initial startup of an affected facility postmarked within 15 days after such date.
 - (4) A notification of any physical or operational change to an existing facility which may increase the emission rate of any air pollutant to which a standard applies, unless that change is specifically exempted under an applicable subpart or in 40 CFR 60.14(e). This notice shall be postmarked 60 days or as soon as practicable before the change is commenced and shall include information describing the precise nature of the change, present and proposed emission control systems, productive capacity of the facility before and after the change, and the expected completion date of the change. The Administrator may request additional relevant information subsequent to this notice.
 - (5) A notification of the date upon which demonstration of the continuous monitoring system performance commences in accordance with 40 CFR 60.13(c). Notification shall be postmarked not less than 30 days prior to such date.

AIR QUALITY TIER I OPERATING PERMIT NUMBER: 029-00003

Permittee: Nu-West Industries, Inc.; Agrium Conda
Phosphate Operations
Location: Soda Springs, Idaho

Date Issued: October 28, 2002
Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

- (6) A notification of the anticipated date for conducting the opacity observations required by 40 CFR 60.11(e)(1) of 40 CFR 60. The notification shall also include, if appropriate, a request for the Administrator to provide a visible emissions reader during a performance test. The notification shall be postmarked not less than 30 days prior to such date.
- (7) A notification that continuous opacity monitoring system data results will be used to determine compliance with the applicable opacity standard during a performance test required by 40 CFR, Part 60.8 in lieu of Method 9 observation data as allowed by 40 CFR 60.11(e)(5) of 40 CFR, Part 60. This notification shall be post-marked not less than 30 days prior to the date of the performance test.

[40 CFR 60.7(a)]

- 8.19.2 Any owner or operator subject to the provisions of 40 CFR 60 shall maintain records of the occurrence and duration of any startup, shutdown, or malfunction in the operation of an affected facility; any malfunction of the air pollution control equipment; or any periods during which a continuous monitoring system or monitoring device is inoperative.

[40 CFR 60.7(b)]

- 8.19.3 Each owner or operator required to install a continuous monitoring device shall submit excess emissions and monitoring systems performance report (excess emissions are defined in applicable subparts) and/or summary report form (see Paragraph (d) of this section) to the Administrator semiannually, except when: more frequent reporting is specifically required by an applicable subpart; or the Administrator, on a case-by-case basis, determines that more frequent reporting is necessary to accurately assess the compliance status of the source. All reports shall be postmarked by the 30th day following the end of each six-month period. Written reports of excess emissions shall include the following information:

- (1) The magnitude of excess emissions computed in accordance with 40 CFR 60.13(h), any conversion factor(s) used, and the date and time of commencement and completion of each time period of excess emissions. The process operating time during the reporting period.
- (2) Specific identification of each period of excess emissions that occurs during startups, shutdowns, and malfunctions of the affected facility. The nature and cause of any malfunction (if known), the corrective action taken or preventative measures adopted.
- (3) The date and time identifying each period during which the continuous monitoring system was inoperative except for zero and span checks and the nature of the system repairs or adjustments.
- (4) When no excess emissions have occurred or the continuous monitoring system(s) have not been inoperative, repaired, or adjusted, such information shall be stated in the report.

[40 CFR 60.7(c)]

- 8.19.4 The summary report form shall contain the information and be in the format shown in figure 1 unless otherwise specified by the Administrator. One summary report form shall be submitted for each pollutant monitored at each affected facility.

- (1) If the total duration of excess emissions for the reporting period is less than 1% of the total operating time for the reporting period and CMS downtime for the reporting period is less than 5% of the total operating time for the reporting period, only the summary report form shall be submitted and the excess emission report described in 40 CFR 60.7(c) need not be submitted unless requested by the Administrator.

AIR QUALITY TIER I OPERATING PERMIT NUMBER: 029-00003**Permittee:** Nu-West Industries, Inc.; Agrium Conda
Phosphate Operations**Date Issued:** October 28, 2002**Location:** Soda Springs, Idaho**Date Expires:** October 28, 2006*The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.*

- (2) If the total duration of excess emissions for the reporting period is 1% or greater of the total operating time for the reporting period or the total CMS downtime for the reporting period is 5% or greater of the total operating time for the reporting period, the summary report form and the excess emission report described in 40 CFR 60.7(c) shall both be submitted.

AIR QUALITY TIER I OPERATING PERMIT NUMBER: 029-00003

Permittee: Nu-West Industries, Inc.; Agrium Conda
Location: Phosphate Operations
Soda Springs, Idaho
Date Issued: October 28, 2002
Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

Summary Report - Gaseous and Opacity Excess Emission and Monitoring System Performance

Pollutant (Circle One: SO₂ / NO_x / TRS / H₂S / CO / Opacity)

Reporting period dates: From _____ to _____

Company: _____

Emission Limitation: _____

Address: _____

Monitor Manufacturer and Model No.: _____

Date of Latest CMS Certification or Audit: _____

Process Unit(s) Description: _____

Total source operating time in reporting period¹: _____

Emission Data Summary¹**CMS Performance Summary¹**

- | | |
|--|--|
| 1. Duration of excess emissions in reporting due to: | 1. CMS downtime in reporting period due to: |
| a. Startup/shutdown _____ | a. Monitor equipment malfunctions _____ |
| b. Control equipment problems _____ | b. Non-Monitor equipment malfunctions _____ |
| c. Process problems _____ | c. Quality assurance calibration _____ |
| d. Other known causes _____ | d. Other known causes _____ |
| e. Unknown causes _____ | e. Unknown causes _____ |
| 2. Total duration of excess emission _____ | 2. Total CMS downtime _____ |
| 3. Total duration of excess emissions x (100) [Total source operating time] % ² | 3. [Total CMS Downtime] x (100) [Total source operating time] % ² |

¹ For opacity, record all times in minutes. For gases, record all times in hours.

² For the reporting period: If the total duration of excess emissions is 1% or greater of the total operating time or the total CMS downtime is 5% or greater of the total operating time, both the summary report form and the excess emission report described in 40 CFR 60.7(c) shall be submitted.

On a separate page, describe any changes since last quarter in CMS, process or controls. I certify that the information contained in this report is true, accurate, and complete.

Name

Signature

Title

Date

[40 CFR 60.7(d)]

AIR QUALITY TIER I OPERATING PERMIT NUMBER: 029-00003

Permittee: Nu-West Industries, Inc.; Agrium Conda
Phosphate Operations
Location: Soda Springs, Idaho

Date Issued: October 28, 2002
Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

- 8.19.5 (1) Notwithstanding the frequency of reporting requirements specified in paragraph (c) of this section, an owner or operator who is required by an applicable subpart to submit excess emissions and monitoring systems performance reports (and summary reports) on a quarterly (or more frequent) basis may reduce the frequency of reporting for that standard to semiannual if the following conditions are met:
- (i) For one full year (e.g., four quarterly or 12 monthly reporting periods) the affected facility's excess emissions and monitoring systems reports submitted to comply with a standard under 40 CFR 60 continually demonstrate that the facility is in compliance with the applicable standard;
 - (ii) The owner or operator continues to comply with all recordkeeping and monitoring requirements specified in Subpart A and the applicable standard; and
 - (iii) The Administrator does not object to a reduced frequency of reporting for the affected facility, as provided in paragraph (e)(2) of this section.
- (2) The frequency of reporting of excess emissions and monitoring systems performance (and summary) reports may be reduced only after the owner or operator notifies the Administrator in writing of his or her intention to make such a change and the Administrator does not object to the intended change. In deciding whether to approve a reduced frequency of reporting, the Administrator may review information concerning the source's entire previous performance history during the required recordkeeping period prior to the intended change, including performance test results, monitoring data, and evaluations of an owner or operator's conformance with operation and maintenance requirements. Such information may be used by the Administrator to make a judgment about the source's potential for noncompliance in the future. If the Administrator disapproves the owner or operator's request to reduce the frequency of reporting, the Administrator will notify the owner or operator in writing within 45 days after receiving notice of the owner or operator's intention. The notification from the Administrator to the owner or operator will specify the grounds on which the disapproval is based. In the absence of a notice of disapproval within 45 days, approval is automatically granted.
- (3) As soon as monitoring data indicate that the affected facility is not in compliance with any emission limitation or operating parameter specified in the applicable standard, the frequency of reporting shall revert to the frequency specified in the applicable standard, and the owner or operator shall submit an excess emissions and monitoring systems performance report (and summary report, if required) at the next appropriate reporting period following the noncomplying event. After demonstrating compliance with the applicable standard for another full year, the owner or operator may again request approval from the Administrator to reduce the frequency of reporting for that standard as provided for in paragraphs (e)(1) and (e)(2) of this section.

[40 CFR 60.7(e)]

AIR QUALITY TIER I OPERATING PERMIT NUMBER: 029-00003

Permittee: Nu-West Industries, Inc.; Agrium Conda
Phosphate Operations
Location: Soda Springs, Idaho

Date Issued: October 28, 2002
Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

8.19.6 Any owner or operator subject to the provisions of 40 CFR 60 shall maintain a file of all measurements, including continuous monitoring system, monitoring device, and performance testing measurements; all continuous monitoring system performance evaluations; all continuous monitoring system or monitoring device calibration checks; adjustments and maintenance performed on these systems or devices; and all other information required by 40 CFR 60 recorded in a permanent form suitable for inspection. The file shall be retained for at least two years following the date of such measurements, maintenance, reports, and records, except as follows;

- (1) This paragraph applies to owners or operators required to install a continuous emissions monitoring system (CEMS) where the CEMS installed is automated, and where the calculated data averages do not exclude periods of CEMS breakdown or malfunction. An automated CEMS records and reduces the measured data to the form of the pollutant emission standard through the use of a computerized data acquisition system. In lieu of maintaining a file of all CEMS subhourly measurements as required under Paragraph (f) of this section, the owner or operator shall retain the most recent consecutive three averaging periods of subhourly measurements and a file that contains a hard copy of the data acquisition system algorithm used to reduce the measured data into the reportable form of the standard.
- (2) This paragraph applies to owners or operators required to install a CEMS where the measured data is manually reduced to obtain the reportable form of the standard, and where the calculated data averages do not exclude periods of CEMS breakdown or malfunction. In lieu of maintaining a file of all CEMS subhourly measurements as required under paragraph (f) of this section, the owner or operator shall retain all subhourly measurements for the most recent reporting period. The subhourly measurements shall be retained for 120 days from the date of the most recent summary or excess emission report submitted to the Administrator.
- (3) The Administrator or delegated authority, upon notification to the source, may require the owner or operator to maintain all measurements as required by paragraph (f) of this section, if the Administrator or the delegated authority determines these records are required to more accurately assess the compliance status of the affected source.

[40 CFR 60.7(f)]

8.19.7 If notification substantially similar to that in paragraph (a) of this section is required by any other State or local agency, sending the Administrator a copy of that notification will satisfy the requirements of paragraph (a) of this section.

[40 CFR 60.7(g)]

PTC General Provisions

8.20 The permittee shall at all times (except as provided in the *Rules*) maintain in good working order and operate as efficiently as practicable, all treatment or control facilities or systems installed or used to achieve compliance with the terms and conditions of this permit and other applicable Idaho laws for the control of air pollution.

[PTC No. 029-00003, General Provision B, 7/12/00]

AIR QUALITY TIER I OPERATING PERMIT NUMBER: 029-00003

Permittee: Nu-West Industries, Inc.; Agrium Conda
Phosphate Operations
Location: Soda Springs, Idaho

Date Issued: October 28, 2002
Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

- 8.21 The maximum allowable operating rate shall be limited to 120% of the average operating rate attained during any performance test period, for which a test protocol has been granted prior approval by the Department, unless (1) the test demonstrates noncompliance; (2) a more restrictive operating limit is specified elsewhere in this permit; or (3) at such an operating rate, emissions would exceed any emissions limit(s) set forth in this permit.

[PTC No. 029-00003, General Provision F, 7/12/00]

AIR QUALITY TIER I OPERATING PERMIT NUMBER: 029-00003

Permittee: Nu-West Industries, Inc.; Agrium Conda
Phosphate Operations
Location: Soda Springs, Idaho

Date Issued: October 28, 2002

Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

9. INSIGNIFICANT ACTIVITIES

Activities and emission units identified as insignificant under IDAPA 58.01.01.317.01(b) are listed in the Tier I operating permit to qualify for a permit shield.

Table 9.1. INSIGNIFICANT EMISSIONS UNITS

Description	Insignificant Activities IDAPA 58.01.01.317.01(b)(i) Citation
One 2,000-gallon gasoline storage tank One 250-gallon diesel fuel storage tank Three 500-gallon portable diesel fuel storage tanks One 1,000-gallon diesel fuel storage tank One 2,000-gallon diesel fuel storage tank One 1,200-gallon diesel fuel storage tank One 500-gallon 10W oil storage tank One 250-gallon 30W oil storage tank One 500-gallon 30W oil storage tank One 250-gallon antifreeze storage tank One 1,900-gallon used oil storage tank One 10,000-gallon dust suppressant storage tank One 17,000-gallon dust suppressant storage tank	3
One 250-gallon propane storage tank Two 500-gallon propane storage tanks	4
Combustion sources, less than 5 MMBtu/hr, exclusively using natural gas, butane, propane, and/or LPG	5
Welding not using more than 1 T/day of welding rod	9
A water cooling tower is used to cool the process steam at the sulfuric acid plant (indirect cooling)	13
An industrial water chlorination system utilizing compress chlorine gas with a daily maximum treatment capacity engineered for 576,000 gpd	16
Space heaters and hot water heaters using natural gas, propane or kerosene and generating less than 5 MMBtu/hr	18
Tanks and pumping equipment for storage and dispensing of acids not greater than 99% H ₂ SO ₄ or H ₃ PO ₄ exist at the facility.	19
Therminol® 55 Heat Transfer Fluid is the HBPO used at the facility (Boiling range: 335°C to 390°C at 760 mm; Reid vapor pressure: 0.16 psi at 100°F)	20
Rolling of cold metal not exceeding 48 inches wide and ½-inch thick	23
2 Hartzell natural gas-fired building air heaters rated at 5.2 MMBtu/hr	30
Ore unloading and transfer (F-Oa-1)	30
Ore storage to Wash Plant (F-Ob-1)	30
Wash plant and grinding mills (S-W-1, S-W-2)	30

- 9.1 There are no monitoring, recordkeeping, or reporting requirements for insignificant emission units or activities beyond those required in the Facility-wide Permit Conditions.

AIR QUALITY TIER I OPERATING PERMIT NUMBER: 029-00003

Permittee: Nu-West Industries, Inc.; Agrum Conda
Phosphate Operations
Location: Soda Springs, Idaho

Date Issued: October 28, 2002
Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

10. TIER I OPERATING PERMIT GENERAL PROVISIONS**General Compliance**

1. The permittee shall comply with all conditions of this permit. Any permit noncompliance constitutes a violation and is grounds for enforcement action; for permit termination, revocation and reissuance, or revision; or for denial of a permit renewal application.
[IDAPA 58.01.01.322.15.a, 5/1/94; 40 CFR 70.6(a)(6)(i)]
2. It shall not be a defense in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the terms and conditions of this permit.
[IDAPA 58.01.01.322.15.b, 5/1/94; 40 CFR 70.6(a)(6)(ii)]
3. Any permittee who fails to submit any relevant facts or who has submitted incorrect information in a permit application shall, upon becoming aware of such failure or incorrect submittal, promptly submit such supplementary facts or corrected information.
[IDAPA 58.01.01.315.01, 5/1/94; 40 CFR 70.5(b)]

Reopening

4. This permit may be revised, reopened, revoked and reissued, or terminated for cause. Cause for reopening exists under any of the circumstances listed in IDAPA 58.01.01.386. Proceedings to reopen and reissue a permit shall follow the same procedures as apply to initial permit issuance and shall affect only those parts of the permit for which cause to reopen exists. Such reopening shall be made as expeditiously as practicable in accordance with IDAPA 58.01.01.360 through 369.
[IDAPA 58.01.01.322.15.c, 5/1/94; IDAPA 58.01.01.386, 3/19/99;
40 CFR 70.7(f)(1) and (2); 40 CFR 70.6(a)(6)(iii)]
5. The filing of a request by the permittee for a permit revision, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.
[IDAPA 58.01.01.322.15.d, 5/1/94; 40 CFR 70.6(a)(6)(iii)]

Property Rights

6. This permit does not convey any property rights of any sort, or any exclusive privilege.
[IDAPA 58.01.01.322.15.e, 5/1/94; 40 CFR 70.6(a)(6)(iv)]

Information Requests

7. The permittee shall furnish all information requested by the Department, within a reasonable time, that the Department may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit.
[Idaho Code §39-108; IDAPA 58.01.01.122 (5/1/94) and 322.15.f (4/5/00);
40 CFR 70.6(a)(6)(v)]

AIR QUALITY TIER I OPERATING PERMIT NUMBER: 029-00003

Permittee: Nu-West Industries, Inc.; Agrium Conda
Phosphate Operations
Location: Soda Springs, Idaho

Date Issued: October 28, 2002
Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

8. Upon request, the permittee shall furnish to the Department copies of records required to be kept by this permit. For information claimed to be confidential, the permittee may furnish such records along with a claim of confidentiality in accordance with Idaho Code §39-342A and applicable implementing regulations including IDAPA 58.01.01.128.
[IDAPA 58.01.01.322.15.g, 5/1/94; IDAPA 58.01.01.128, 4/5/00; 40 CFR 70.6(a)(6)(v)]

Severability

9. The provisions of this permit are severable, and if any provision of this permit to any circumstance is held invalid, the application of such provision to other circumstances, and the remainder of this permit shall not be affected thereby.
[IDAPA 58.01.01.322.15.h, 5/1/94; 40 CFR 70.6(a)(5)]

Changes Requiring Permit Revision or Notice

10. The permittee may not commence construction or modification of any stationary source, facility, major facility, or major modification without first obtaining all necessary permits to construct or an approval under IDAPA 58.01.01.213, or complying with IDAPA 58.01.01.220 through 223. The permittee shall comply with IDAPA 58.01.01.380 through 386 as applicable.
[IDAPA 58.01.01.200-223, 4/5/00; IDAPA 58.01.01.322.15.i, 380-386, 3/19/99; 40 CFR 70.4(b)(12), (14) and (15), and 70.7(d) and (e)]
11. Changes that are not addressed or prohibited by the Tier I operating permit require a Tier I operating permit revision if such changes are subject to any requirement under Title IV of the CAA, 42 USC Section 7651 through 7651c, or are modifications under Title I of the CAA, 42 USC Section 7401 through 7515. Administrative amendments (IDAPA 58.01.01.381), minor permit modifications (IDAPA 58.01.01.383), and significant permit modifications (IDAPA 58.01.01.382) require a revision to the Tier I operating permit. IDAPA 58.01.01.502(b)(10) changes are authorized in accordance with IDAPA 58.01.01.384. Off-permit changes and required notice are authorized in accordance with IDAPA 58.01.01.385.
[IDAPA 58.01.01.381-385, 3/19/99; IDAPA 58.01.01.209.05, 5/1/94; 40 CFR 70.4(b)(14) and (15)]

Federal and State Enforceability

12. Unless specifically identified as a "State-only" provision, all terms and conditions in this permit, including any terms and conditions designed to limit a source's potential to emit, are enforceable: (i) by the Department in accordance with state law; and (ii) by the United States or any other person in accordance with federal law.
[IDAPA 58.01.01.322.15.j, 5/1/94; 40 CFR 70.6(b)(1) and (2)]
13. Provisions specifically identified as a "State-only" provision are enforceable only in accordance with state law. "State-only" provisions are those that are not required under the Federal Clean Air Act or under any of its applicable requirements or those provisions adopted by the state prior to federal approval.
[Idaho Code §39-108; IDAPA 58.01.01.322.15.k, 3/23/98]

AIR QUALITY TIER I OPERATING PERMIT NUMBER: 029-00003

Permittee: Nu-West Industries, Inc.; Agrium Conda
Phosphate Operations
Location: Soda Springs, Idaho

Date Issued: October 28, 2002
Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

Inspection and Entry

14. Upon presentation of credentials, the permittee shall allow the Department or an authorized representative of the Department to do the following:
- 14.1 Enter upon the permittee's premises where a Tier I source is located or emissions related activity is conducted, or where records are kept under conditions of this permit;
- 14.2 Have access to and copy, at reasonable times, any records that are kept under the conditions of this permit;
- 14.3 Inspect at reasonable times any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit; and
- 14.4 As authorized by the Idaho Environmental Protection and Health Act, sample or monitor, at reasonable times, substances or parameters for the purpose of determining or ensuring compliance with this permit or applicable requirements.

[Idaho Code §39-108; IDAPA 58.01.01.322.15.i, 3/19/99; 40 CFR 70.6(c)(2)]

New Requirements During Permit Term

15. The permittee shall comply with applicable requirements that become effective during the permit term on a timely basis.

[IDAPA 58.01.01.322.10, 4/5/00; IDAPA 58.01.01.314.10.a.ii, 5/1/94;
40 CFR 70.6(c)(3) citing 70.5(c)(8)]

Fees

16. The owner or operator of a Tier I source shall pay annual registration fees to the Department in accordance with IDAPA 58.01.01.525 through IDAPA 58.01.01.538.

[IDAPA 58.01.01.322.15.n, 5/1/94; 40 CFR 70.6(a)(7)]

Certification

17. All documents submitted to the Department shall be certified in accordance with IDAPA 58.01.01.123 and comply with IDAPA 58.01.01.124.

[IDAPA 58.01.01.322.15.o, 5/1/94; 40 CFR 70.6(a)(3)(iii)(A); 40 CFR 70.5(d)]

Renewal

18. The owner or operator of a Tier I source shall submit an application to the Department for a renewal of this permit at least six months before, but no earlier than 18 months before, the expiration date of this operating permit. To ensure that the term of the operating permit does not expire before the permit is renewed, the owner or operator is encouraged to submit a renewal application nine months prior to the date of expiration.

[IDAPA 58.01.01.313.03, 4/5/00; 40 CFR 70.5(a)(1)(iii)]

AIR QUALITY TIER I OPERATING PERMIT NUMBER: 029-00003

Permittee: Nu-West Industries, Inc.; Agrium Conda
Phosphate Operations
Location: Soda Springs, Idaho

Date Issued: October 28, 2002
Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

- 18.1 If a timely and complete application for a Tier I operating permit renewal is submitted, but the Department fails to issue or deny the renewal permit before the end of the term of this permit, then all the terms and conditions of this permit including any permit shield that may have been granted pursuant to IDAPA 58.01.01.325 shall remain in effect until the renewal permit has been issued or denied.
[IDAPA 58.01.01.322.15.p, 5/1/94; 40 CFR 70.7(b)]

Permit Shield

19. Compliance with the terms and conditions of the Tier I operating permit, including those applicable to all alternative operating scenarios and trading scenarios, shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that:
- 19.1 Such applicable requirements are included and are specifically identified in the Tier I operating permit; or
- 19.1.1 The Department has determined that other requirements specifically identified are not applicable and all of the criteria set forth in IDAPA 58.01.01.325.01(b) have been met.
- 19.2 The permit shield shall apply to permit revisions made in accordance with IDAPA 58.01.01.381.04 (administrative amendments incorporating the terms of a permit to construct), IDAPA 58.01.01.382.04 (significant modifications), and IDAPA 58.01.01.384.03 (trading under an emissions cap).
- 19.3 Nothing in this permit shall alter or affect the following:
- 19.3.1 Any administrative authority or judicial remedy available to prevent or terminate emergencies or imminent and substantial dangers;
- 19.3.2 The liability of an owner or operator of a source for any violation of applicable requirements prior to or at the time of permit issuance;
- 19.3.3 The applicable requirements of the acid rain program, consistent with 42 U.S.C. Section 7651(g)(a); and
- 19.3.4 The ability of EPA to obtain information from a source pursuant to Section 114 of the CAA; or the ability of the Department to obtain information from a source pursuant to Idaho Code §39-108 and IDAPA 58.01.01.122.
[Idaho Code §39-108 and 112; IDAPA 58.01.01.122, 322.15.m, 325, 5/1/94;
IDAPA 58.01.01.381.04, 382.04, 383.05, 384.03, 385.03, 3/19/99; 40 CFR 70.6(f)]

Compliance Schedule and Progress Reports

20. For each applicable requirement for which the source is not in compliance, the permittee shall comply with the compliance schedule incorporated in this permit.
- 20.1 For each applicable requirement that will become effective during the term of this permit and that provides a detailed compliance schedule, the permittee shall comply with such requirements in accordance with the detailed schedule.

AIR QUALITY TIER I OPERATING PERMIT NUMBER: 029-00003

Permittee: Nu-West Industries, Inc.; Agrium Conda
Phosphate Operations
Location: Soda Springs, Idaho

Date Issued: October 28, 2002

Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

- 20.2 For each applicable requirement that will become effective during the term of this permit that does not contain a more detailed schedule, the permittee shall meet such requirements on a timely basis.
- 20.3 For each applicable requirement with which the permittee is in compliance, the permittee shall continue to comply with such requirements.
[IDAPA 58.01.01.322.10, 4/5/00; IDAPA 58.01.01.314.9, 10, 5/1/94; 40 CFR 70.6(c)(3) and (4)]

Periodic Compliance Certification

21. The permittee shall submit compliance certifications during the term of the permit for each emissions unit to the Department and the EPA as follows:
- 21.1 Compliance certifications for all emissions units shall be submitted annually beginning 12 months from the permit issuance date, or more frequently if specified by the underlying applicable requirement or elsewhere in this permit by the Department;
- 21.2 The compliance certification for each emissions unit shall address all of the terms and conditions contained in the Tier I operating permit that are applicable to such emissions unit including emissions limitations, standards, and work practices;
- 21.3 The compliance certification shall be in an itemized form providing the following information (provided that the identification of applicable information may cross-reference the permit or previous reports as applicable):
- 21.3.1 The identification of each term or condition of the Tier I operating permit that is the basis of the certification;
- 21.3.2 The identification of the method(s) or other means used by the owner or operator for determining the compliance status with each term and condition during the certification period, and whether such methods or other means provide continuous or intermittent data. Such methods and other means shall include, at a minimum, the methods and means required by this Tier I operating permit. If necessary, the owner or operator shall identify any other material information that must be included in the certification to comply with Section 113(c)(2) of the CAA which prohibits knowingly making a false certification or omitting material information;
- 21.3.3 The status of compliance with the terms and conditions of the permit for the period covered by the certification, based on the method or means designated in Paragraph 21.3.2 above. The certification shall identify each deviation and take it into account in the compliance certification. The certification shall also identify as possible exceptions to compliance any periods during which compliance is required and in which an excursion or exceedance as defined under 40 CFR 64 occurred;
- 21.3.4 Such other facts as the Department may require to determine the compliance status of the source.
- 21.4 All original compliance certifications shall be submitted to the Department and a copy of all compliance certifications shall be submitted to the EPA.
[IDAPA 58.01.01.322.11, 5/1/94; 40 CFR 70.6(c)(5)(III) as amended, 62 Fed. Reg. 54900, 54946, 10/22/97; 40 CFR 70.6(c)(5)(iv)]

AIR QUALITY TIER I OPERATING PERMIT NUMBER: 029-00003

Permittee: Nu-West Industries, Inc.; Agrum Conda
Phosphate Operations
Location: Soda Springs, Idaho

Date Issued: October 28, 2002
Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

False Statements

22. No person shall knowingly make any false statement, representation, or certification in any form, notice, or report required under this permit, or any applicable rule or order in force pursuant thereto.
[IDAPA 58.01.01.125, 3/23/98]

No Tampering

23. No person shall knowingly render inaccurate any monitoring device or method required under this permit or any applicable rule or order in force pursuant thereto.
[IDAPA 58.01.01.126, 3/23/98]

Annual and Semiannual Monitoring Reports

24. In addition to all applicable reporting requirements identified in this permit, the permittee shall submit reports of any required monitoring at least every six months starting six months from the date of permit issuance. All instances of deviations from this operating permit's requirements must be clearly identified in the report. All required reports must be certified in accordance with IDAPA 58.01.01.123.
[IDAPA 58.01.01.322.15.q, 3/23/98; IDAPA 58.01.01.322.08.c, 4/5/00; 40 CFR 70.6(a)(3)(iii)]

Reporting Deviations and Excess Emissions

25. The permittee shall promptly report all deviations from permit requirements including upset conditions, their probable cause, and any corrective actions or preventive measures taken. For excess emissions, the report shall be made in accordance with IDAPA 58.01.01.130-136. For all other deviations, the report shall be made in accordance with IDAPA 58.01.01.322.08.c, unless otherwise specified in this permit.
[IDAPA 58.01.01.322.15.q, 3/23/98; IDAPA 58.01.01.135, 4/5/00; 40 CFR 70.6(a)(3)(iii)]

Permit Revision Not Required

26. No permit revision shall be required under any approved economic incentives, marketable permits, emissions trading, and other similar programs or processes for changes that are provided for in the permit.
[IDAPA 58.01.01.322.05.b, 4/5/00; 40 CFR 70.6(a)(8)]

Emergency

27. In accordance with IDAPA 58.01.01.332, an "emergency" as defined in IDAPA 58.01.01.008., constitutes an affirmative defense to an action brought for noncompliance with such technology-based emissions limitation if the conditions of IDAPA 58.01.01.332.02 are met.
[IDAPA 58.01.01.332.01, 3/19/99; 40 CFR 70.6(g)]